

Comment Report

63-31656

1. csaxton 5/11/2012 10:36:20 AM POU
Comment: Updated Shape
2. csaxton 5/11/2012 10:36:40 AM POU
Comment: Updated PLS
3. csaxton 5/11/2012 10:47:13 AM POD
Comment: Updated Shape
4. csaxton 5/11/2012 Review
Comment: I agree with the overlap review conducted by the field examiner. This diversion rate licensed under this right (0.25 cfs) combined with right 63-31759 (0.21 cfs) does not exceed the measured capacity of the well which is 0.61 cfs.
5. csaxton 5/11/2012 Water Bearing Zone Condition
Comment: The ground water is diverted outside the area where ground water is tributary to the Boise River upstream from Star Bridge. Drop the water bearing zone conditions as we have already decided not to put it on new permits in this area.
6. csaxton 5/11/2012 Fire Protection
Comment: Field examiner recommended dropping Fire Protection as a purpose of use and said that water is not diverted for fire hydrants under this permit.
7. dgibson 6/8/2005 Extension of Time
Comment: Request for Extension of Time granted extending proof deadline to 6/1/2007 based on due diligence.
8. dgibson 5/14/2007 Extension of Time
Comment: An extension of time was filed and granted based on due diligence. Proof deadline extended to June 1, 2012.
9. lgraves 3/20/2003 Legal Notice Remarks
Comment: Applicant agrees to mitigate consumptive use in the future as needed. Domestic use is for 10 homes and yards in Highplains Estates Subdivision. Water bearing zone to be appropriated is from 100 to 600 feet.
10. lgraves 3/20/2003 Comment/Analysis
Comment: The p/d is proposed in Blk 1, next to the SW corner of Lot 2, Highplains Estates Subdivision. Applicant also has application 63-31563 filed for irrigation of 50 acres in the W1/2 NE S21, which is currently in processing hold. The lot sizes average .75 acre. No other rights are used.